

March 5, 2019

SUPPLEMENTAL/ BID BULLETIN

NAME OF THE PROJECT: CONTRACT FOR THE SUPPLY, DELIVERY, AND REPLACEMENT OF TWO (2) UNITS FILTER STRUCTURE FILTER MEDIA WITH COMMISSIONING AND TESTING

This Addendum No. 1 is issued to modify or amend the Checklist of Requirements for Bidders, Technical Specification, Section II- Instruction to Bidders, Section VI. Schedule of Requirements, and Section VII. Technical Requirements of the Bidding Documents, and under the Contract for the Supply, Delivery, and Replacement of Two (2) Units Filter Structure Filter Media with Commissioning and Testing. This shall form an integral part of the Bidding Documents.

Amended Checklist of Requirements for Bidders:

To amend Technical Requirement #20 - Certification from the bidder to provide additional filter media for each AFM grade and Anthracite to compensate for any media loss due to fines and errors on estimated quantities.

To add Technical Requirement #23- Certification from the bidder that they had conducted filtration testing of Activated Filter Media (AFM) to any water utilities including but not limited to local Water District's, Maynilad, and Manila Water, maintaining and operating water treatment facilities.

Amended Technical Specifications:

3. Filtration rate=12(m³/hr)/m² with at least 24 hours run time

Delivery Period: 90 days upon receipt of Purchase Order.

Each of the two filter should be provided with the following filter media height for each AFM Grade and Anthracite.

AFM Grade 1= .72meters

AFM Grade 2= .09 meters

Anthracite= .09 meters

a.) Suppliers should provide additional filter media for each AFM grade and Anthracite to compensate for any media loss due to fines and errors on estimated quantities.

b.) Supplier should provide a filter prototype model containing exact specified height of different AFM filter media grade and Anthracite for filtration testing for a period of one month.

Amended Section II- Instruction to Bidder:

To amend Technical Requirement #20 - Certification from the bidder to provide additional filter media for each AFM grade and Anthracite to compensate for any media loss due to fines and errors on estimated quantities.

To add Technical Requirement #23- Certification from the bidder that they had conducted filtration testing of Activated Filter Media (AFM) to any water utilities including

but not limited to Local Water District's, Maynilad, Manila Water, maintaining and operating water treatment facilities.

Amended Section VI. Schedule of Requirements

3. Filtration rate = $12(\text{m}^3/\text{hr})/\text{m}^2$ with at least 24 hours run time

Delivery Period: 90 days upon receipt of Purchase Order.

Each of the two filter should be provided with the following filter media height for each AFM Grade and Anthracite.

AFM Grade 1 = .72 meters

AFM Grade 2 = .09 meters

Anthracite = .09 meters

a.) Suppliers should provide additional filter media for each AFM grade and Anthracite to compensate for any media loss due to fines and errors on estimated quantities.

b.) Supplier should provide a filter prototype model containing exact specified height of different AFM filter media grade and Anthracite for filtration testing for a period of one month.

Amended Section VII. Technical Specifications

3. Filtration rate = $12(\text{m}^3/\text{hr})/\text{m}^2$ with at least 24 hours run time

Delivery Period: 90 days upon receipt of Purchase Order.

Each of the two filter should be provided with the following filter media height for each AFM Grade and Anthracite.

AFM Grade 1 = .72 meters

AFM Grade 2 = .09 meters

Anthracite = .09 meters

a.) Suppliers should provide additional filter media for each AFM grade and Anthracite to compensate for any media loss due to fines and errors on estimated quantities.

b.) Supplier should provide a filter prototype model containing exact specified height of different AFM filter media grade and Anthracite for filtration testing for a period of one month.

For guidance and information of all concerned.

ATTY. DANTE A. ARCANGELES

Chairperson

Bids and Awards Committee

[Signature]
CERTIFIED TRUE COPY