

February 20, 2019

## ***SUPPLEMENTAL/ BID BULLETIN***

### **NAME OF THE PROJECT: CONTRACT FOR THE SUPPLY, DELIVERY, INSTALLATION, AND COMMISSIONING OF SUPERVISORY CONTROL AND DATA ACQUISITION PROGRAMMABLE LOGIC CONTROLLER**

This Addendum No. 1 is issued to modify or amend the Section II- Instruction to Bidders, Section VI- Schedule of Requirements, Section VII- Technical Specifications of the Bidding Documents, and Checklist of Requirements for Bidders under the Contract for the Supply, Delivery, Installation, and Commissioning of Supervisory Control and Data Acquisition Programmable Logic Controller. This shall form an integral part of the Bidding Documents.

#### **Amended Section II- Instruction to Bidder:**

Amended Technical Requirement 12.1(xix)- Two (2) years Warranty Certificate free of charge for software, program and design upgrading (upgrading means that the supplier will have to accommodate future expansion, additional features and equipment to be installed within the period covered) after commissioning.

To add Technical Requirement 12.1(xxvi) - Certificate issued by Metro Roxas Water District that the bidder has conducted a site inspection of all field instruments and project site coordinates.

#### **Amended Section VI- Schedule of Requirements:**

Amended Technical Specification on 4.6 - A panel PC with touch screen shall be installed at WTP main control room, Arcabalo and Lawa-an station, 15" TFT, 1024x768, Intel Baytrail J1900 4-core CPU support VGA and HDMI output or its equivalent, WIFI is optional Linux System, uninterrupted running with 24 hours Built-in Cloud SCADA, 2GB DDR3 RAM and 32GB SSD, USB2.0, USB3.0, RJ-45, COM port, VGA, HDMI, Audio port with 12 Vdc power supply input.

#### **Amended Section VII- Technical Specification:**

Amended Technical Specification on 4.6 - A panel PC with touch screen shall be installed at WTP main control room, Arcabalo and Lawa-an station, 15" TFT, 1024x768, Intel Baytrail J1900 4-core CPU support VGA and HDMI output or its equivalent, WIFI is optional Linux System, uninterrupted running with 24 hours Built-in Cloud SCADA, 2GB DDR3 RAM and 32GB SSD, USB2.0, USB3.0, RJ-45, COM port, VGA, HDMI, Audio port with 12 Vdc power supply input.

#### **Amended Checklist of Requirements for Bidders:**

Amended Technical Requirement #19 - Two (2) years Warranty Certificate free of charge for software, program and design upgrading (upgrading means that the supplier will have to accommodate future expansion, additional features and equipment to be installed within the period covered) after commissioning.

To add Technical Requirement #26 - Certificate issued by Metro Roxas Water District that the bidder has conducted a site inspection of all field instruments and project site coordinates.

**Amended Technical Specification:**

Amended Technical Specification on 4.6 - A panel PC with touch screen shall be installed at WTP main control room, Arcabalo and Lawa-an station, 15" TFT, 1024x768, Intel Baytrail J1900 4-core CPU support VGA and HDMI output or its equivalent, WIFI is optional Linux System, uninterrupted running with 24 hours Built-in Cloud SCADA, 2GB DDR3 RAM and 32GB SSD, USB2.0, USB3.0, RJ-45, COM port, VGA, HDMI, Audio port with 12 Vdc power supply input.

For guidance and information of all concerned.

**ATTY. DANTE A. ARCANGELES**  
Chairperson  
Bids and Awards Committee

*Received*  
*12.*  
*NESTLE CONDESA*  
*Feb 23, 2019*

## Bid Supplement Abstract

Reference Number	<b>5994619</b>
Title	CONTRACT FOR THE SUPPLY, DELIVERY, INSTALLATION, AND COMMISSIONING OF SUPERVISORY CONTROL AND DATA ACQUISITION PROGRAMMABLE LOGIC CONTROLLER
Category	Water and Waste Water Treatment Supply & Disposal
Type	Addendum
Bid Supplement No.	5994619-01
Title	CONTRACT FOR THE SUPPLY, DELIVERY, INSTALLATION, AND COMMISSIONING OF SUPERVISORY CONTROL AND DATA ACQUISITION PROGRAMMABLE LOGIC CONTROLLER
Area of Delivery/Location	Capiz
Delivery Period/Contract Duration	150 Day/s
Contact Person	MARJORIE ALVAREZ DELA CRUZ
Description	Amendments on Technical Requirement No. 19, 26, and Technical Specification 4.6

Note: Click the document name to view the attachment.

Document Name	Document Type	Content	Format
<a href="#">Addendum</a>	Electronic	Bid Bulletin	Legal 8.5 x 14

[Back](#)

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

### Amended Checklist of Requirements for Bidders:

Amended Technical Requirement #19 - Two (2) years Warranty Certificate free of charge for software, program and design upgrading (upgrading means that the supplier will have to accommodate future expansion, additional features and equipment to be installed within the period covered) after commissioning.